



NOTES:

1. DETECTABLE WARNING PATTERN TILE SHALL BE YELLOW TRUNCATED-DOME TYPE.
2. RAMP SLOPES SHALL NOT BE STEEPER THAN 12H:1V.
3. A 4' x 4' LANDING AT THE TOP OF THE RAMP WITH 2% SLOPE IN ALL DIRECTIONS AND A 4' X 4' CLEAR SPACE WITHIN THE CROSSWALK AREA.
4. PLACEMENT OF DRAINAGE STRUCTURES, JUNCTION BOXES OR OTHER OBSTRUCTIONS WITHIN/ OR FRONT OF RAMP OR LANDING IS PROHIBITED.
5. THIS RAMP SHALL BE USED WITH HIGH BACK AND ROLLED CURB.

\\Standards\2010-Standards\2-Concrete\Perpend_Type3.dwg

CITY OF LEWISTON, IDAHO PUBLIC WORKS DEPARTMENT	
SIDEWALK RAMP TYPE 3	
APPROVED FOR PUBLICATION <i>Shawn Stibler</i> 9/1/10 City Engineer	DWG. NO. 2-13
Date	